

## Annex A (informative)

### Model pro forma for documentation of a fire risk assessment

**A.1** This annex contains a model pro forma for documentation of an FRA in England and Wales. (Electronic versions, including modified pro formas for use in Scotland and Northern Ireland, are available online at <https://documentportal.bsigroup.com> using access code PAS 79:2020.) If the pro forma is properly completed by a competent person, the format and scope of the FRA will be suitable and sufficient to satisfy the recommendations of this PAS.

*NOTE* Enforcement of fire safety legislation is the prerogative of the enforcing authority charged by legislation with the responsibility to do so. Each enforcing authority is autonomous. There is sometimes debate as to the legal interpretation of what constitutes the significant findings of an FRA. However, the format of the pro forma contained in this annex, being part of a BSI PAS, is considered by the National Fire Chiefs Council to be one suitable format for recording the significant findings of a suitable and sufficient FRA, although many other formats would also be acceptable.

**A.2** The format of a documented FRA may vary from that shown in this annex, provided that the recommendations of each clause of this PAS are satisfied. For example, in the case of means of escape, compliance with Annex C necessitates that the key factors in Table C.1 are explicitly addressed in the documented FRA, but not all the specific issues shown in Table C.1 and in the pro forma contained in this annex need necessarily be included in all documented FRAs conforming to the recommendations of this PAS, as they might not all constitute “significant findings”. It is, however, necessary for compliance with this PAS, that the specific issues have, at least, been considered by the fire risk assessor while carrying out the FRA.

**A.3** Similarly, the prompt-list of fire hazards shown in the pro forma may be expanded. This might be appropriate, for example, if there are significant fire hazards for which no headings are included in the pro forma.

**A.4** Where description of any fire hazards or fire precautions is considered appropriate, this can be recorded under the appropriate “Relevant information (including description of arrangements and deficiencies observed)” heading in the pro forma. These sections can also be used to set out justification for acceptance of standards of any fire protection measures that depart significantly from a prescriptive norm (see **10.4**). Information recorded can include positive findings as well as deficiencies, as this helps to contextualize the assessment of risk.

**A.5** While it might not be essential to record further information in every section of the pro forma, care needs to be taken to ensure that the pro forma does not become purely a tick-list with inadequate supporting information. Such an FRA is unlikely to satisfy fire safety legislation, nor would it meet the recommendations of this PAS.

**A.6** For many types of housing, obtaining relevant information for completion of the pro forma in this annex can prove challenging (e.g. because there is no one who can provide the information available on the premises). Under these circumstances, the “No” box should be ticked and an explanation recorded under “Relevant information (including description of arrangements and deficiencies observed)”.

**A.7** Within the pro forma in this annex, for each main topic, the clause within this PAS that provides guidance on that topic is shown in parentheses alongside the topic heading. This is for the guidance of the user of this PAS, and the clause references need not be shown in the documented fire assessment provided to the dutyholder.

**A.8** For further guidance on the use of the pro forma, an exemplar of a completed FRA is contained in Annex G.

**Template instructions:**

The header and footer fields are locked and cannot be altered. Clicking in either of these fields can cause the cursor to jump to a later place in the document.

The NA/Yes/No boxes can be populated by clicking in the auto-complete field in the centre of the box, or by positioning the cursor outside the auto-complete field and entering your own choice of character.

## REGULATORY REFORM (FIRE SAFETY) ORDER 2005 FIRE RISK ASSESSMENT

---

Responsible person (e.g. employer) or person having control of the premises:

Address of premises:

Person(s) consulted:

Assessor:

Report validated by:

Date of fire risk assessment:

Date of previous fire risk assessment:

Suggested date for review:

This report is intended to assist you in compliance with Article 9 of the Regulatory Reform (Fire Safety) Order 2005 (the "Fire Safety Order"), which requires that a risk assessment be carried out.

**GENERAL INFORMATION**

**1. THE PREMISES** *(Clause 12)*

1.1 Number of floors at ground level and above:

Number of floors entirely below ground level:

Floors on which car parking is provided:

1.2 Number of flats:

1.3 Brief details of construction and approximate age of building:

1.4 Occupancy:

**2. THE OCCUPANTS** *(Clause 12)*

2.1 Approximate maximum number of employees at any one time:

2.2 Approximate maximum number of residents and visitors at any one time:

**3. OCCUPANTS ESPECIALLY AT RISK FROM FIRE** *(Clause 12)*

3.1 Sleeping occupants:

3.2 Occupants in remote areas and lone workers:

3.3 Others:

**4. FIRE LOSS EXPERIENCE**

A large, empty rectangular box with a thin black border, intended for the user to provide details about their fire loss experience.

**5. OTHER RELEVANT INFORMATION**

A large, empty rectangular box with a thin black border, intended for the user to provide any other relevant information.

**6. RELEVANT FIRE SAFETY LEGISLATION**

6.1 The following fire safety legislation applies to these premises:

6.2 The above legislation is enforced by:

6.3 Other legislation that makes significant requirements for fire precautions in these premises [other than the Building Regulations 2010 (as amended)]:

6.4 The other legislation referred to above is enforced by:

6.5 Is there an alterations notice in force? Yes  No

Relevant information and deficiencies observed:

**FIRE HAZARDS AND THEIR ELIMINATION OR CONTROL**

**7. ELECTRICAL SOURCES OF IGNITION** *(Clause 13 and Annex B)*

7.1 Are reasonable measures taken to prevent fires of electrical origin? Yes  No

7.2 More specifically:

a) Are fixed installations periodically inspected and tested? N/A  Yes  No

b) Is portable appliance testing carried out? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**8. SMOKING** *(Clause 13 and Annex B)*

8.1 Are reasonable measures taken to prevent fires as a result of smoking? Yes  No

8.2 More specifically:

a) Is smoking prohibited in appropriate areas? N/A  Yes  No

b) Are there suitable arrangements for those who wish to smoke? N/A  Yes  No

c) Did the smoking policy appear to be observed at time of inspection? N/A  Yes  No

d) Are "No smoking" signs provided in the common areas? Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**9. ARSON** *(Clause 13 and Annex B)*

9.1 Does basic security against arson by outsiders appear reasonable<sup>1)</sup>? Yes  No

9.2 Is there an absence of unnecessary fire load in close proximity to the premises or available for ignition by outsiders? Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**10. PORTABLE HEATERS AND HEATING AND VENTILATION INSTALLATIONS**  
*(Clause 13 and Annex B)*

10.1 Is there satisfactory control over the use of portable heaters? N/A  Yes  No

10.2 Are fixed heating and ventilation installations subject to regular maintenance? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**11. COOKING** *(Clause 13 and Annex B)*

11.1 Are reasonable measures taken to prevent fires as a result of cooking? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

<sup>1)</sup> Reasonable only in the context of this fire risk assessment. If specific advice on security (including security against arson) is required, this should be obtained from a security specialist.



**12. LIGHTNING** *(Clause 13 and Annex B)*

12.1 Does the building have a lightning protection system? Yes  No

Relevant information and deficiencies observed:

**13. HOUSEKEEPING** *(Clause 13 and Annex B)*

13.1 Is the overall standard of housekeeping adequate? Yes  No

13.2 More specifically:

a) Do combustible materials appear to be separated from ignition sources? Yes  No

b) Is unnecessary accumulation or inappropriate storage of combustible materials or waste avoided? Yes  No

c) Are gas and electricity intake/meter cupboards adequately secured and kept clear of combustible materials? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**14. HAZARDS INTRODUCED BY OUTSIDE CONTRACTORS AND BUILDING WORKS** *(Clause 13 and Annex B)*

14.1 Is there satisfactory control over works carried out in the building by contractors? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**15. DANGEROUS SUBSTANCES<sup>2)</sup> (Clause 13)**

15.1 Are the general fire precautions adequate to address the hazards associated with dangerous substances used or stored within the premises<sup>3)</sup>? N/A  Yes  No

Relevant information and deficiencies observed:

**16. OTHER SIGNIFICANT FIRE HAZARDS THAT WARRANT CONSIDERATION**

16.1 Hazards:

Relevant information and deficiencies observed:

---

<sup>2)</sup> For the purpose of this risk assessment and the Fire Safety Order, dangerous substances are primarily explosive, highly flammable or flammable substances and oxidizing agents.

<sup>3)</sup> Small quantities with negligible impact on the appropriate fire precautions need not be taken into account.

**FIRE PROTECTION MEASURES****17. MEANS OF ESCAPE** *[Clause 15c) and Annex C]*

17.1 Is the design and maintenance of the means of escape considered adequate? Yes  No

17.2 More specifically:

a) Are there reasonable distances of travel:

– where there is escape in a single direction? N/A  Yes  No

– where there are alternative means of escape? N/A  Yes  No

b) Is there adequate provision of exits? N/A  Yes  No

c) Do fire exits open in the direction of escape, where necessary? N/A  Yes  No

d) Are the arrangements provided for securing exits satisfactory? N/A  Yes  No

e) Is the fire-resisting construction (including any glazing) protecting escape routes and staircases of a suitable standard and maintained in sound condition? N/A  Yes  No

f) Is the fire resistance of doors to staircases and the common areas considered adequate, and are the doors maintained in sound condition? N/A  Yes  No

g) Are suitable self-closing devices fitted to doors in the common areas? N/A  Yes  No

h) Is the fire resistance of doors to meter cupboards/store rooms/plant rooms in the common areas considered adequate, and are they adequately secured and/or fitted with suitable self-closing devices? N/A  Yes  No

i) Is the fire resistance of flat entrance doors considered adequate, and are doors maintained in sound condition? N/A  Yes  No

j) Are suitable self-closing devices fitted to flat entrance doors and, where fitted, maintained in good working order? N/A  Yes  No

- k) Are there adequate smoke control provisions to protect the common escape routes, where necessary? N/A  Yes  No
- l) Are all escape routes clear of obstructions? N/A  Yes  No
- m) Are all fire exits easily and immediately openable? N/A  Yes  No
- n) Is it considered that the premises are provided with reasonable arrangements for means of escape for disabled people? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

## 18. MEASURES TO LIMIT FIRE SPREAD AND DEVELOPMENT [Clause 15g]

18.1 Is it considered that there is/are:

- a) adequate levels of compartmentation between floors and between flats and the common escape routes? Yes  No
- b) reasonable limitation of linings to escape routes that might promote fire spread? Yes  No
- c) as far as can reasonably be ascertained, reasonable fire separation within any roof space? N/A  Yes  No
- d) adequately fire protected service risers and/or ducts in common areas, that will restrict the spread of fire and smoke? N/A  Yes  No

18.2 As far as can reasonably be ascertained, are fire dampers provided as necessary to protect critical means of escape against passage of fire, smoke and products of combustion in the early stages of a fire<sup>4), 5)</sup>? N/A  Yes  No

<sup>4)</sup> This fire risk assessment will not necessarily identify all minor fire stopping issues that might exist within the building. If you become aware of other fire stopping issues, or are concerned about the adequacy of fire stopping, you may wish to consider arranging for an invasive survey by a competent specialist.

<sup>5)</sup> A full investigation of the design of heating, ventilation and air conditioning systems is outside the scope of this fire risk assessment.

Relevant information (including description of arrangements and deficiencies observed):

**19. EMERGENCY ESCAPE LIGHTING** *[Clause 15e]*

19.1 Has a reasonable standard of emergency escape lighting been provided<sup>6)</sup>? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**20. FIRE SAFETY SIGNS AND NOTICES** *[Clause 15d]*

20.1 Is there a reasonable standard of fire safety signs and notices? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**21. MEANS OF GIVING WARNING IN CASE OF FIRE** *[Clause 15b]*

21.1 Is a reasonable fire detection and fire alarm system provided in the common areas, where necessary<sup>7)</sup>? N/A  Yes  No

21.2 If there is a communal fire detection and fire alarm system, does it extend into the dwellings? N/A  Yes  No

<sup>6)</sup> Based on visual inspection, but no test of illuminance levels or verification of full compliance with relevant British Standards carried out.

<sup>7)</sup> Based on visual inspection, but no audibility tests or verification of full compliance with relevant British Standard carried out.

21.3 Where appropriate, has a fire alarm zone plan been provided? N/A  Yes  No

21.4 Where appropriate, are there adequate arrangements for silencing and resetting an alarm condition? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

Relevant information on false alarm experience (if known):

**22. MANUAL FIRE EXTINGUISHING APPLIANCES** *[Clause 15f]*

22.1 Is there reasonable provision of manual fire extinguishing appliances? N/A  Yes  No

22.2 Are all fire extinguishing appliances readily accessible? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**23. RELEVANT AUTOMATIC FIRE EXTINGUISHING SYSTEMS<sup>8)</sup> [Clause 15h]**

23.1 Type of fixed system:

Relevant information and deficiencies observed:

**24. OTHER RELEVANT FIXED SYSTEMS AND EQUIPMENT<sup>9)</sup> [Clause 15i]**

24.1 Type of fixed system:

Relevant information and deficiencies observed:

24.2 Are there appropriately sited facilities for electrical isolation of any photovoltaic (PV) cells, with appropriate signage, to assist the fire and rescue service?      N/A     Yes     No

Relevant information (including description of arrangements and deficiencies observed):

<sup>8)</sup> Relevant to life safety and this risk assessment (as opposed to property protection).

<sup>9)</sup> Relevant to life safety and this risk assessment (as opposed to property protection).

**MANAGEMENT OF FIRE SAFETY**

**25. PROCEDURES AND ARRANGEMENTS** *(Clause 16)*

25.1 Safety assistance:

The competent person(s) appointed under Article 18 of the Fire Safety Order to assist the responsible person in undertaking the preventive and protective measures (i.e. relevant general fire precautions) is:

25.2 Fire safety at the premises is managed by<sup>10)</sup>:

25.3 Is there a suitable record of the fire safety arrangements? Yes  No

Relevant information (including description of arrangements and deficiencies observed):

25.4 Evacuation strategy

- Stay put
- Simultaneous evacuation
- Other (please specify below)

Comment:

---

<sup>10)</sup> This is not intended to represent a legal interpretation of responsibility, but merely reflects the managerial arrangement in place at the time of this risk assessment.



25.5 Are procedures in the event of fire appropriate and properly documented, where appropriate<sup>11)</sup>? Yes  No

Relevant information (including description of arrangements and deficiencies observed):

25.6 Are routine in-house inspections of fire precautions undertaken (e.g. in the course of health and safety inspections)? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**26. TRAINING AND DRILLS** *[Clause 16h]*

26.1 Are all staff given adequate fire safety instruction and training? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

26.2 When the employees of another employer work in the premises, is appropriate information on fire risks and fire safety measures provided? N/A  Yes  No

<sup>11)</sup> Based on brief review of procedures at the time of this fire risk assessment. In-depth review of documentation is outside the scope of this fire risk assessment, unless otherwise stated.

Relevant information (including description of arrangements and deficiencies observed):

**27. TESTING AND MAINTENANCE** *[Clause 16j)]*

27.1 Is there adequate maintenance of the premises? Yes  No

Relevant information (including description of arrangements and deficiencies observed):

27.2 Is weekly testing and periodic servicing of the fire detection and fire alarm system undertaken? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

27.3 Are monthly and annual testing routines in place for the emergency escape lighting? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

27.4 Is annual maintenance of fire extinguishing appliances undertaken? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

27.5 Are six-monthly inspection and annual testing of rising mains undertaken? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

27.6 Are weekly and monthly testing, six-monthly inspection, and annual inspection and testing undertaken of lift(s) provided for use by firefighters or evacuation of disabled people (evacuation lifts)? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

27.7 Other relevant inspections or tests:

Relevant information (including description of arrangements and deficiencies observed):

**28. RECORDS** *[Clause 16k]*

28.1 Are there appropriate records of:

a) Fire alarm tests (where relevant)? N/A  Yes  No

b) Emergency escape lighting tests? N/A  Yes  No

c) Maintenance and testing of other fire protection systems and equipment? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

**29. PREMISES INFORMATION BOX** *[Clause 15c]*

29.1 Is there a suitably located premises information box for the fire and rescue service?<sup>12)</sup> N/A  Yes  No

29.2 Are there arrangements to keep the premises information box up to date?<sup>12)</sup> N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

---

<sup>12)</sup> Normally applicable only to sheltered and extra care housing.

**30. ENGAGEMENT WITH RESIDENTS** *[Clause 16l]*

30.1 Has information on fire procedures been disseminated to residents? N/A  Yes  No

30.2 Is fire safety information disseminated to residents? N/A  Yes  No

Relevant information (including description of arrangements and deficiencies observed):

## FIRE RISK ASSESSMENT

The following simple risk level estimator is based on a commonly used risk level estimator:

Potential consequences of fire → Likelihood of fire ↓	Slight harm	Moderate harm	Extreme harm
Low	Trivial risk	Tolerable risk	Moderate risk
Medium	Tolerable risk	Moderate risk	Substantial risk
High	Moderate risk	Substantial risk	Intolerable risk

Taking into account the fire prevention measures observed at the time of this risk assessment, it is considered that the hazard from fire (likelihood of fire) at these premises is:

Low  Medium  High

In this context, a definition of the above terms is as follows:

- Low:** Unusually low likelihood of fire as a result of negligible potential sources of ignition.
- Medium:** Normal fire hazards (e.g. potential ignition sources) for this type of occupancy, with fire hazards generally subject to appropriate controls (other than minor shortcomings).
- High:** Lack of adequate controls applied to one or more significant fire hazards, such as to result in significant increase in likelihood of fire.

Taking into account the nature of the premises and the occupants, as well as the fire protection and procedural arrangements observed at the time of this fire risk assessment, it is considered that the consequences for life safety in the event of fire would be:

Slight harm  Moderate harm  Extreme harm

In this context, a definition of the above terms is as follows:

- Slight harm:** Outbreak of fire unlikely to result in serious injury or death of any occupant.
- Moderate harm:** Outbreak of fire could foreseeably result in injury (including serious injury) of one or more occupants, but is unlikely to result in multiple fatalities.
- Extreme harm:** Significant potential for serious injury or death of one or more occupants.

Accordingly, it is considered that the risk to life from fire at these premises is:

Trivial  Tolerable  Moderate  Substantial  Intolerable

Comments:

A suitable risk-based control plan should involve effort and urgency that are proportional to risk. The following risk-based control plan is based on one advocated for general health and safety risks:

Risk level	Action and timescale
<b>Trivial</b>	No action is required, and no detailed records need be kept.
<b>Tolerable</b>	No major additional controls required. However, there might be a need for improvements that involve minor or limited cost.
<b>Moderate</b>	It is essential that efforts are made to reduce the risk. Risk reduction measures should be implemented within a defined time period.  Where moderate risk is associated with consequences that constitute extreme harm, further assessment might be required to establish more precisely the likelihood of harm as a basis for determining the priority for improved control measures.
<b>Substantial</b>	Considerable resources might have to be allocated to reduce the risk. If the building is unoccupied, it should not be occupied until the risk has been reduced. If the building is occupied, urgent action should be taken.
<b>Intolerable</b>	Building (or relevant area) should not be occupied until the risk is reduced.

**Note that, although the purpose of this section is to place the fire risk in context, the above approach to risk assessment is subjective and for guidance only. All hazards and deficiencies identified in this report should be addressed by implementing all recommendations contained in the following action plan. The fire risk assessment should be repeated regularly.**

**ACTION PLAN**

It is considered that the following actions should be implemented in order to reduce fire risk to, or maintain it at, the following level:

Trivial       Tolerable

Definition of priorities (where applicable):

Item	Recommendation	Priority	Timescale
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			



Item	Recommendation	Priority	Timescale
11.			
12.			
13.			
14.			
15.			
<b>Interim measures (where appropriate)</b>			
16.			
17.			
18.			
19.			
20.			

## REFERENCES

